Certificate of Conformity (COC)

	All and a state of the state of
Certificate Holder	: NINGBO DEYE ESS TECHNOLOGY CO., LTD No.568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang, China
Manufacturer's Name	: NINGBO DEYE ESS TECHNOLOGY CO., LTD No.568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang, China
and address	
Date of Original Issue	: 16/01/2025
Date of Last Revision	
Date of Expiry	: 15/01/2028
Certificate Number	: PCS-24-20027
Product : Lithium-ion Rechargeable Battery System	
Ratings : See page 2	
Brand : Deve	
Model : BOS-GX-Pro (X=25, 30, 35, 40, 45, 50, 55, 60, 65, 70, 75, 80, 85) Test Laboratory: SGS-CSTC Standards Technical Services Co., Ltd. Shenzhen Branch	

Testing Report(s): SZES240600424201

Test Standard(s): VDE-AR-E 2510-50:2017-05

This is to certify that the product has been tested and was found to comply with the requirements of the standard(s).

ferry Xiao

Jerry Xiao Certification Officer

SGS Testing & Control Services Singapore Pte Ltd 30 Boon Lay Way #03-01 Singapore 609957

SGS



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at https://www.sgs.com/en/terms-and-conditions and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.

Ratings

BOS-G25-Pro: 256.0 V d.c., 100 Ah, 25.60kWh; BOS-G30-Pro: 307.2 V d.c., 100 Ah, 30.72kWh; BOS-G35-Pro: 358.4 V d.c., 100 Ah, 35.84kWh; BOS-G40-Pro: 409.6 V d.c., 100 Ah, 40.96kWh BOS-G45-Pro: 460.8 V d.c., 100 Ah, 46.08kWh; BOS-G50-Pro: 512.0 V d.c., 100 Ah, 51.20kWh BOS-G55-Pro: 563.2 V d.c., 100 Ah, 56.32kWh; BOS-G60-Pro: 614.4 V d.c., 100 Ah, 61.44kWh BOS-G65-Pro: 665.6 V d.c., 100 Ah, 66.56kWh; BOS-G70-Pro: 716.8 V d.c., 100 Ah, 71.68kWh BOS-G75-Pro: 768.0 V d.c., 100 Ah, 76.80kWh; BOS-G80-Pro: 819.2 V d.c., 100 Ah, 81.92kWh



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <u>https://www.sgs.com/en/terms-and-conditions</u> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.

SGSSGS